

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1130:211 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Honeywell International Inc. 1500 W. Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4000 Fax (847) 797-3664

DESIGN: Models TC806D1011, TC806D1018, TC806D1023, TC806D1031, TC806D1049, and TC806D1056, duct smoke detector. Unit consists of an enclosure, electrical components, sampling and exhaust tubes and listed photoelectric smoke detector sensor. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, air velocity rating, and UL label.

APPROVAL: Listed as a duct smoke detector units when used with separately listed compatible fire alarm control units. Intended for use in HVAC systems having air velocities between 500 to 4000 ft/min. *Models TC806D1049 and TC806D1056 are suitable for use in ducts having air velocities between 100 and 4000 ft/min. Refer to listee's Installation Instruction Manual for details.

*Rev. 08-04-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**